

Annexure D

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 608/DRDA

Dated: 12-04-2024

It is certified that an inspection team headed by ...Mr. BINOD KUMAR..... (Name of Officers with designation) from District water & sanitation committee Siwan inspected the DAUD ALAM PUBLIC SCHOOL (A SCHOOL OF STATUS), BARHOGA KOTHI, JAMO BAZAR, SIWAN, BIHAR-841413. (Name & Address of the school) on 12-4-2024 (Date of inspection) and on the basis of water Test sample Report (Attached) from Public Health Engineering Department (PHED Lab) certified that the DAUD ALAM PUBLIC SCHOOL (A SCHOOL OF STATUS) (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition if the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

The above is valid for a period ofONE YEAR.....

Signature with seal:  12-4-24
उप विकास आयुक्त
सिवान

Name : Mr. Binod Kumar

Designation : DC, B.W.S.C., SIWAN


Name & Address of Department/ Office: DRDA Office,
Siwan

To

The DAUD ALAM PUBLIC SCHOOL (A SCHOOL OF STATUS), BARHOGA KOTHI, JAMO BAZAR, SIWAN, BIHAR-841413.

(Name & Address of the Institution)

Note: the certificate is to be issued by authorized officer / PHED Lab / local bodies



Government of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory:-Siwan

Sample Collected bt- Shamsher Ali


Sample Receiving date:- 12.06.2024

Sl No.	Date of Testing	Block	Panchayat	Ward	Name of School	Parameters															
						ph.	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO2	SO2	F	As	Total Coll	
1	12.06.2024	Goreyakothi	Barhoga Kothi	-	Daud Alam Public School (A School of Status)	7.2	1	-	230	90.2	24.4	12.2	35.6	92.3	BDL	BDL	BDL	BDL	0	<1.1	
IS: 10500:2012 (2nd Revision)						6.5-8.5	1	-	200	200	75	30	250	200	0.3	45	1	0.01			
						8.5	5	-	500	600	200	100	1000	600	1	NR	1.5	NR			
Acceptance limits																					
Permissible limits																					

D. L. P. H. Division, Siwan

Chemist
D.L.L.P.H Division, Siwan

12.06.2024


 Director
 DAP School, (A School of Status)
 Barhoga Kothi, Jano Bazar, Siwan - 841413