

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 51

Date : 03/02/2026

It is certified that an inspection team headed by Abhishek Kumar Ray
Incharge Medical Officer (Name of Officers
with designation) from C.H.C. Goriyakothi (Name of
Department/Office) inspected the Daud Alam Public School (A School
of Status), Barhoga Kotui, Jamo Bazar, Siwan (Name & Address of
the School) on 02-02-2026 and found that the Daud Alam Public
School (A School of Status) (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year. As per supply, Public Health
Engineering Department District level water testing
level Laboratory -
(photo copy attached)

Signature with Seal : Abhishek
Name : 03/02/2026
Designation : DR-Abhishek Kr. Ray
MOIC

To
Daud Alam Public School
(A School of Status)
Barhoga Kotui, Jamo Bazar, Siwan (Bihar) - 841413

Incharge Medical Officer
C.H.C. Goriyakothi
Siwan.

(Name & Address of the Institution)

Government of Bihar

Public Health Engineering Department

District Level Water Testing Laboratory:- Siwan

Date:- 29.12.2025

Sample Collected by Amir Suhail

SL. No.	Block	Panchyat	Village	Name of Habitation	Location of Source	Parameters														
						pH	Turb. EC	TDS	TH	Ca	Mg	Cl	Alka. Fe	NO ₃	SO ₄	F	As	Total Coli		
1	Siwan	Goreyakoithi	Barhoha Kothi	Jamo Bazar	Daud Alam Public School(A School of Status)	6.92	0.4	178	105	28.6	10.2	25.6	79.5	0.22	BDL	10.00	0.19			<1.1
Desirable Limits						6.5-	5.0	500	200	75	30	250	200	1.0	45	200	1.0	0.01		
Permissible Limits						8.5	NR	-	600	200	100	1000	600	NR	NR	400	1.5	NR		

All parameters are under disirable limits

Handwritten signature

Chemist D.L.L.
P.H. Division, Siwan